CITY OF FARMINGTON
800 Municipal Drive
Farmington, NM 87401-2663
(505) 599-1373
Fax (505) 599-1377
http://www.fmtn.org

IMMEDIATE ATTENTION

CONSTRUCTION OF FIRE STATION ONE AND A FIRE ADMINISTRATION BUILDING
PROJECT # RPSTA1
CONTRACT CONTROL # 14-100215

ADDENDUM FIVE

SEPTEMBER 25, 2013

Notice to Bidders/Offerors: The above referenced request for proposals is hereby amended as follows:

The following questions or requests for clarification were submitted. Following each question or request for clarification is the response.

1. Under the tiling section 9300, Schluter, Jolly and Quadec edge protection is called out in the stainless steel finish. My catalog does not show that the Jolly comes in a stainless steel finish. Can I substitute the Schiene, stainless steel for the Jolly? They have the same profile. *Schluter Schiene or equal, in stainless steel finish, shall be used at the locations where tile edge trim is indicated instead of the specified Schluter Jolly trim.*

2. *At wall type 5 on sheet A2.5, provide mineral wool fire blocking in accordance with IBC 2009 section 717.2 requirements in stud cavities at upper floor slab. At wall types 2, 2A, 2B, 2C, and 2D provide a 1hr rated UL approved fire stopping assembly at all wall penetrations, and a 1 hr rated UL approved head of wall assembly at the top of the wall.*

Receipt of this addendum shall be noted on Form AF-1 (a) in Tab I – Bidding Requirements for the above referenced RFP.

If your offer has already been submitted to this office, and this addendum will affect your offer quote, please contact this office and we will return your offer. Any offers that have been received, and are not requested to be returned will remain in this office unopened until October 1, 2013 at 2:00 p.m.

Rosalyn Potter

Rosalyn Potter, CPPB
Phone: (505) 599-1365
Fax: (505) 599-1377
Email: rpotter@fmtn.org

PURCHASING