CITY OF FARMINGTON
800 Municipal Drive
Farmington, NM 87401-2663
(505) 599-1373
Fax (505) 599-1377
http://www.fmtn.org

IMMEDIATE ATTENTION
RECLOSERS
BID #14-100982

ADDENDUM TWO

October 28, 2013

Notice to Bidders: The above referenced bid is hereby amended as follows:

The following questions or requests for clarifications were submitted regarding this bid. Following each question or request for clarification is the response.

1. For the NOVA15 Interface do you prefer the Type NOVA AP, with auxiliary-powered interface 120 VAC closing (14-pin & 2-pin receptacles) or the Type NOVA CP, with control-powered interface (19-pin receptacle), 120 VAC Heater? *We prefer the NOVA 15 Interface with auxiliary-powered, 120Vac Closing (14-Pin and 2-Pin) Receptacles.*

2. Do the source and load side arrestors need to be factory installed and factory wired? *Six (6) arresters need to be factory Installed and the ground wired. Raptor Guard for each bushing is also required.*

3. Please confirm City of Farmington is providing a 120V Transformer to supply power to control. *City of Farmington will not provide 120Vac transformer to supply power to control. The specifications call for potential transformers (P.T.) (7.97KV, 1-KVA) to be included in the bid.*

4. Please confirm City of Farmington is providing external potential transformers for each phase to monitor phase voltage and low voltage trip. *Specifications require internal voltage sensing for each phase located inside the recloser. City of Farmington will not supply external P.T.*

5. The Form 6 has the following I/O options:

   a. Standard contacts: 3 input/5 output, 12-250Vac, standard connection.
   b. Additional contacts: universal inputs, 8 input/8 output, 12-250Vac, standard connection.

CITY OF FARMINGTON
800 Municipal Drive
Farmington, NM 87401-2663
(505) 599-1373
Fax (505) 599-1377
http://www.fmtn.org

Do you have a preference on the number of contacts? *We prefer b: Additional contacts: universal inputs, 8 input/8 output, 12-250Vac, standard connection.*

Receipt of this addendum shall be noted on the Invitation to Bid form, page 2, for the above referenced bid.

If your bid has already been submitted to this office, and this addendum will affect your bid quote, please contact this office and we will return your bid. Any bids that have been received, and are not requested to be returned will remain in this office unopened until November 4, 2013 at 2:00 p.m.

Rosalyn Potter, CPPB
Buyer II
Phone: (505) 599-1365
Fax: (505) 599-1377
Email: rpotter@fmtn.org